DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5143BP0261
Registration Number
Registriernummer

Field of Application ***Anwendungsbereich***	products of gas supply *Produkte der Gasversorgung*
Distributor ***Vertreiber***	KANDO Service GmbH Bahnhofsplatz 1, A-4600 Wels
Product Category ***Produktart***	Greasing and sealing materials: PTFE thread sealing tape for gas installations and hot water (5143)
Product description ***Produktbezeichnung***	PTFE monofilament for sealing threaded pipes
Model ***Modell***	Sealthread 240 / Threadseal 240
Test reports ***Prüfberichte***	Type testing: 24-00072-AB01 from 09.09.2024 (EBI) Laboratory control test: 24-00072-KP01 from 07.10.2025 (EBI)
Test basis ***Prüfgrundlagen***	DIN EN 751-3 (01.03.2024)
Date of Expiry / File No. ***Ablaufdatum / Aktenzeichen***	31.03.2029 / 26-0395-GNR

70028-04-A-DE

14.07.2026 Fi F-1/2 i.A. Dr.
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DAkkS
Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvgw-cert.com
www.dvgw-cert.com

Type *Typ*	Technical Data *Technische Daten*	Remarks *Bemerkungen*
Sealthread 240 / Threadseal 240	Class: F und G	for fine threads </= DN 10 and coarse threads > DN 10 and </= DN 50

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

Application: at least 30 turns with coarse threads or 18 turns with fine threads with lubricant as an installation aid; alignment is permissible

Pressure range for gas installations: <= 5 bar
Pressure range for hot water: <= 7 bar
Pressure range for liquid gas storage: <= 20 bar
Pressure range for gas appliances: <= 200 mbar

Temperature range for gas installations: -20...+70 °C
Temperature range for hot water: up to 125 °C
Temperature range for liquid gas storage: -20...+125 °C
Temperature range for gas appliances: -20...+125 °C

The installation must be checked for leaks after assembly.

DVGW CERT